

VERSION: 2.4

4/15/2010

Manufacturer: Arada

Appliance Type: Cat (Cat, Non-Cat, Pellet)

Model: Farrington 16

Date: 2/21/2017

Run: 3

Temp. Units: F (F or C)

Weight Units: lb (kg or lb)

Control #: 035-S-075-1

Test Duration: 250

Burn Category: 2

Wood Moisture (% DRY): 19.3

Wood Moisture (% wet): 16.18

Load Weight (lb wet): 10.70

Burn Rate (dry kg/h): 0.98

Total Particulate Emissions: 8.31 g

Fuel Data

D. Fir

HHV: 19,810 kJ/kg

%C: 48.73

%H: 6.87

%O: 43.90

%Ash: 0.50

Elapsed Time (min)	Fuel Weight Remaining (lb)	Averages		Temp. (F)		
		241.4	69.9	9.63	11.23	0.38
		Flue Gas	Room Temp	Flue Gas Composition (%)		
				O2	CO2	CO
0	10.7	229.0	72.0	14.52	5.80	0.02
10	10.1	245.0	70.0	14.35	6.40	0.02
20	9.4	239.0	70.0	12.87	8.27	0.03
30	9.0	246.0	69.0	12.01	9.26	0.05
40	8.5	253.0	69.0	10.71	10.78	0.06
50	7.9	290.0	69.0	6.34	15.11	0.12
60	6.8	330.0	69.0	5.32	14.99	2.62
70	5.7	320.0	69.0	5.13	15.65	1.51
80	4.6	320.0	70.0	4.92	15.03	3.90
90	3.7	304.0	70.0	5.07	15.60	1.19
100	3.2	268.0	70.0	9.65	11.19	0.03
110	2.9	255.0	70.0	10.64	10.13	0.03
120	2.6	247.0	70.0	10.64	10.21	0.03
130	2.3	240.0	70.0	10.58	10.39	0.03
140	1.9	245.0	70.0	9.15	12.06	0.06
150	1.6	241.0	70.0	9.51	11.40	0.03
160	1.4	229.0	70.0	9.42	11.43	0.04
170	1.2	220.0	70.0	9.69	11.09	0.02
180	1.0	208.0	70.0	10.04	10.75	0.02
190	0.9	201.0	70.0	9.50	11.27	0.02
200	0.7	198.0	70.0	9.60	11.21	0.02
210	0.6	195.0	70.0	10.32	10.60	0.02
220	0.5	191.0	70.0	10.27	10.57	0.03
230	0.3	189.0	70.0	9.79	11.23	0.02
240	0.2	187.0	70.0	10.07	10.90	0.02
250	0.0	186.0	70.0	10.38	10.57	0.02

Manufacturer: Arada
 Model: Farringdon 16
 Date: 2/21/2017
 Run: 3
 Control #: 035-S-075-1
 Test Duration: 250 min

	HHV	LHV
Eff	79.5%	85.9%
Comb Eff	96.0%	96.0%
HT Eff	82.8%	89.5%
Output	15,379	kJ/h
Burn Rate	0.98	kg/h
Grams CO	231	g
Input	19,348	kJ/h
MC wet	16.18	
Averages	0.38	11.23

Ultimate CO:
 CO2-ult 19.64
 Fo
 1.063

INPUT DATA				Oxygen Calculation			Input
Elapsed Time	Weight Remaining (kg)	% CO [e]	% CO2 [d]	Excess Air EA	Total O2	Calc. % O2 [g]	Flue Gas (°C)
0	4.85	0.02	5.80	237.5%	20.56	14.75	109.4
10	4.58	0.02	6.40	206.0%	20.52	14.11	118.3
20	4.26	0.03	8.27	136.7%	20.39	12.11	115.0
30	4.08	0.05	9.26	111.0%	20.33	11.04	118.9
40	3.86	0.06	10.78	81.2%	20.22	9.41	122.8
50	3.58	0.12	15.11	29.0%	19.93	4.76	143.3
60	3.09	2.62	14.99	11.5%	19.78	3.48	165.6
70	2.59	1.51	15.65	14.5%	19.81	3.40	160.0
80	2.09	3.90	15.03	3.8%	19.69	2.71	160.0
90	1.68	1.19	15.60	17.0%	19.83	3.64	151.1
100	1.45	0.03	11.19	75.1%	20.20	8.99	131.1
110	1.32	0.03	10.13	93.3%	20.27	10.12	123.9
120	1.18	0.03	10.21	91.8%	20.26	10.04	119.4
130	1.04	0.03	10.39	88.5%	20.25	9.85	115.6
140	0.86	0.06	12.06	62.1%	20.14	8.05	118.3
150	0.73	0.03	11.40	71.9%	20.19	8.77	116.1
160	0.64	0.04	11.43	71.3%	20.18	8.73	109.4
170	0.54	0.02	11.09	76.8%	20.21	9.11	104.4
180	0.45	0.02	10.75	82.4%	20.23	9.47	97.8
190	0.41	0.02	11.27	74.0%	20.19	8.91	93.9
200	0.32	0.02	11.21	74.9%	20.20	8.98	92.2
210	0.27	0.02	10.60	85.0%	20.24	9.63	90.6
220	0.23	0.03	10.57	85.3%	20.24	9.66	88.3
230	0.14	0.02	11.23	74.6%	20.20	8.96	87.2
240	0.09	0.02	10.90	79.9%	20.22	9.31	86.1
250	0.00	0.02	10.57	85.5%	20.24	9.66	85.6

		Air Fuel Ratio (A/F)			
Overall Heating Efficiency:	79.5%	Dry Molecular Weight (Md)		30.15	
Combustion Efficiency:	96.0%	Dry Moles Exhaust Gas (Nr):		340.28	%HC
Heat Transfer Efficiency:	82.8%	Air Fuel Ratio (A/F)		9.75	0.88

Heat Output: 14,589 Btu/h 15,379 kJ/h
Heat Input: 18,353 Btu/h 19,348 kJ/h

2

Burn Duration: 4.166666667 h

Burn Rate: 2.2 lb/h 1.0 kg/h

Stack Temp: 241.9 Deg. F 116.6 Deg. C

21.0	98.4%	83.7%	82.4%	11.0	1.70	64.88	0.04	64.88
Data	Combust	Heat	Net	Air	Wet Wt	% Wet	Dry Wt.	% Dry
Room	Eff	Transfer	Eff	Fuel	Now	Consumed	Now	Consumed
Temp (°C)	%	%	%	Ratio	Wt	x	Wtdn	y
22.2	100.5%	80.1%	80.5%	20.4	4.85	0.00	4.07	0.00
21.1	100.4%	79.9%	80.2%	18.5	4.58	5.61	3.84	5.61
21.1	100.1%	82.3%	82.4%	14.3	4.26	12.15	3.57	12.15
20.6	99.9%	82.6%	82.5%	12.8	4.08	15.89	3.42	15.89
20.6	99.8%	83.3%	83.1%	11.0	3.86	20.56	3.23	20.56
20.6	99.4%	83.8%	83.3%	7.8	3.58	26.17	3.00	26.17
20.6	87.7%	81.9%	71.8%	6.5	3.09	36.45	2.59	36.45
20.6	92.7%	82.7%	76.7%	6.8	2.59	46.73	2.17	46.73
21.1	83.0%	81.8%	67.9%	6.0	2.09	57.01	1.75	57.01
21.1	94.1%	83.3%	78.4%	7.0	1.68	65.42	1.41	65.42
21.1	100.0%	83.0%	83.0%	10.6	1.45	70.09	1.22	70.09
21.1	100.0%	82.9%	82.9%	11.7	1.32	72.90	1.10	72.90
21.1	100.0%	83.2%	83.3%	11.6	1.18	75.70	0.99	75.70
21.1	100.0%	83.6%	83.6%	11.4	1.04	78.50	0.87	78.50
21.1	99.8%	84.2%	84.0%	9.8	0.86	82.24	0.72	82.24
21.1	100.0%	84.0%	84.0%	10.4	0.73	85.05	0.61	85.05
21.1	99.9%	84.5%	84.4%	10.4	0.64	86.92	0.53	86.92
21.1	100.1%	84.7%	84.7%	10.7	0.54	88.79	0.46	88.79
21.1	100.1%	85.0%	85.0%	11.0	0.45	90.65	0.38	90.65
21.1	100.1%	85.4%	85.5%	10.5	0.41	91.59	0.34	91.59
21.1	100.1%	85.5%	85.5%	10.6	0.32	93.46	0.27	93.46
21.1	100.1%	85.4%	85.5%	11.2	0.27	94.39	0.23	94.39
21.1	100.0%	85.5%	85.5%	11.2	0.23	95.33	0.19	95.33
21.1	100.1%	85.8%	85.9%	10.6	0.14	97.20	0.11	97.20
21.1	100.1%	85.8%	85.8%	10.9	0.09	98.13	0.08	98.13
21.1	100.1%	85.7%	85.8%	11.2	0.00	100.00	0.00	100.00

Combustion Efficiency: 96.0%
 Total Input (kJ): 80,615 76,459 (Btu)
 Total Output (kJ): 64,081 60,778 (Btu)
 Efficiency: 79.5%
 Total CO (g): 231.11

Load Weight (kg):
 Fuel Heating:
 Value in kJ/kg - CV:

81368	4.06	6.87	2.74	19810.00	16.18	79.64	21.12	2.87
Fuel Properties			Oxygen /16= [c]	Calorific Value	Mw Moisture Fuel Burnt	Mass Balance (moles/100 mole dry		
Total Input	Carbon /12= [a]	Hydrogen /1= [b]				[h]	[u]	[w]
0	4.06	6.87	2.74	19810.00	16.18	79.43	21.07	1.43
7157	4.06	6.87	2.74	19810.00	16.18	79.47	21.08	1.58
4144	4.06	6.87	2.74	19810.00	16.18	79.59	21.11	2.04
3390	4.06	6.87	2.74	19810.00	16.18	79.65	21.13	2.29
4144	4.06	6.87	2.74	19810.00	16.18	79.75	21.15	2.67
6404	4.06	6.87	2.74	19810.00	16.18	80.01	21.22	3.75
8288	4.06	6.87	2.74	19810.00	16.18	78.91	20.93	4.43
8288	4.06	6.87	2.74	19810.00	16.18	79.44	21.07	4.28
7534	4.06	6.87	2.74	19810.00	16.18	78.36	20.79	4.80
5274	4.06	6.87	2.74	19810.00	16.18	79.57	21.11	4.18
3014	4.06	6.87	2.74	19810.00	16.18	79.79	21.16	2.76
2260	4.06	6.87	2.74	19810.00	16.18	79.72	21.14	2.50
2260	4.06	6.87	2.74	19810.00	16.18	79.72	21.15	2.52
2637	4.06	6.87	2.74	19810.00	16.18	79.73	21.15	2.56
2637	4.06	6.87	2.74	19810.00	16.18	79.83	21.18	2.98
1884	4.06	6.87	2.74	19810.00	16.18	79.80	21.17	2.81
1507	4.06	6.87	2.74	19810.00	16.18	79.80	21.17	2.82
1507	4.06	6.87	2.74	19810.00	16.18	79.78	21.16	2.73
1130	4.06	6.87	2.74	19810.00	16.18	79.76	21.16	2.65
1130	4.06	6.87	2.74	19810.00	16.18	79.80	21.17	2.78
1130	4.06	6.87	2.74	19810.00	16.18	79.79	21.16	2.76
753	4.06	6.87	2.74	19810.00	16.18	79.75	21.15	2.61
1130	4.06	6.87	2.74	19810.00	16.18	79.74	21.15	2.61
1130	4.06	6.87	2.74	19810.00	16.18	79.79	21.17	2.77
1884	4.06	6.87	2.74	19810.00	16.18	79.77	21.16	2.69
753	4.06	6.87	2.74	19810.00	16.18	79.75	21.15	2.60

Moisture Content MCwb: 16.18

Moisture of Wood (wet basis): 16.18
Initial Dry Weight Wtdo (kg): 4.07
Moisture Content Dry 19.30

Dry kg : 4.07
CA: 48.73
HY: 6.87
OX: 43.90

4.85
HHV LHV HHV LHV
19810.00 18328.69 Btu/lb 8522.48 7885.21

9.77	0.04	0.29	39.84	35.97	0.90	0.07	300.33	34.38
flue gas)		kg Wood per 100 mole dfp	Moles per kg of Dry Wood					
[j]	[k]	Nk	CO2	O2	CO	HC	N2	H2O
4.95	-0.02	0.14	40.82	103.77	0.14	-0.15	559.03	34.82
5.45	-0.02	0.16	40.81	89.95	0.13	-0.13	506.78	34.77
7.04	-0.02	0.20	40.74	59.64	0.15	-0.07	392.08	34.67
7.89	-0.01	0.23	40.64	48.45	0.22	-0.05	349.56	34.61
9.18	-0.01	0.27	40.61	35.47	0.23	-0.02	300.42	34.57
12.87	0.01	0.37	40.46	12.76	0.32	0.03	214.26	34.47
14.46	0.38	0.44	34.01	7.89	5.94	0.85	179.06	32.81
14.27	0.21	0.43	36.76	7.99	3.55	0.50	186.60	33.51
15.36	0.56	0.48	31.47	5.67	8.16	1.18	164.05	32.16
14.01	0.17	0.42	37.54	8.75	2.86	0.40	191.51	33.72
9.50	-0.01	0.27	40.74	32.75	0.11	-0.04	290.48	34.60
8.61	-0.01	0.25	40.74	40.72	0.12	-0.05	320.59	34.62
8.68	-0.01	0.25	40.74	40.06	0.12	-0.05	318.10	34.62
8.83	-0.01	0.26	40.74	38.61	0.12	-0.04	312.64	34.61
10.26	0.00	0.30	40.62	27.12	0.20	-0.01	268.91	34.55
9.68	-0.01	0.28	40.74	31.34	0.11	-0.03	285.18	34.59
9.71	-0.01	0.28	40.70	31.09	0.14	-0.03	284.14	34.58
9.41	-0.01	0.27	40.78	33.49	0.07	-0.04	293.39	34.61
9.12	-0.01	0.26	40.78	35.92	0.08	-0.05	302.60	34.62
9.56	-0.01	0.28	40.78	32.26	0.07	-0.04	288.75	34.61
9.51	-0.01	0.27	40.78	32.66	0.07	-0.04	290.28	34.61
9.00	-0.01	0.26	40.78	37.05	0.08	-0.05	306.85	34.62
8.98	-0.01	0.26	40.74	37.21	0.12	-0.04	307.36	34.61
9.53	-0.01	0.28	40.78	32.53	0.07	-0.04	289.77	34.61
9.25	-0.01	0.27	40.78	34.83	0.07	-0.05	298.47	34.61
8.97	-0.01	0.26	40.78	37.28	0.08	-0.05	307.71	34.62

10.72	389.47	3767.01	2847.34	2771.87	2740.51	3599.20	3317.95	294.20
Moisture Present	Stack Temp K	Heat Content Change - Ambient to Stack Temperature Flue Gas Constituent						Room Temp K
		CO2	O2	CO	N2	CH4	H2O	
10.72	382.59	3433.98	2602.09	2534.70	2505.69	3266.83	3034.57	295.37
10.72	391.48	3838.65	2903.82	2827.42	2795.31	3662.54	3384.63	294.26
10.72	388.15	3702.50	2802.85	2729.61	2698.51	3528.20	3267.70	294.26
10.72	392.04	3882.52	2937.01	2859.74	2827.26	3704.40	3423.31	293.71
10.72	395.93	4041.83	3054.95	2973.95	2940.31	3862.03	3559.83	293.71
10.72	416.48	4891.19	3680.61	3579.04	3539.39	4709.30	4282.86	293.71
10.72	438.71	5823.19	4361.29	4235.85	4189.99	5651.88	5067.22	293.71
10.72	433.15	5588.85	4190.70	4071.39	4027.05	5413.65	4870.87	293.71
10.72	433.15	5567.70	4174.35	4055.38	4011.25	5394.24	4851.68	294.26
10.72	424.26	5194.61	3902.00	3792.60	3750.94	5016.65	4537.88	294.26
10.72	404.26	4363.54	3291.79	3202.96	3167.06	4183.26	3833.48	294.26
10.72	397.04	4066.28	3072.32	2990.59	2956.82	3887.82	3579.67	294.26
10.72	392.59	3884.11	2937.50	2860.04	2827.60	3707.46	3423.63	294.26
10.72	388.71	3725.17	2819.67	2745.91	2714.64	3550.55	3287.18	294.26
10.72	391.48	3838.65	2903.82	2827.42	2795.31	3662.54	3384.63	294.26
10.72	389.26	3747.85	2836.50	2762.21	2730.77	3572.91	3306.67	294.26
10.72	382.59	3476.31	2634.79	2566.72	2537.31	3305.69	3072.94	294.26
10.72	377.59	3273.49	2483.78	2420.27	2392.40	3106.91	2897.82	294.26
10.72	370.93	3004.20	2282.78	2225.21	2199.42	2844.05	2664.53	294.26
10.72	367.04	2847.71	2165.71	2111.55	2086.98	2691.86	2528.57	294.26
10.72	365.37	2780.78	2115.58	2062.86	2038.82	2626.90	2470.33	294.26
10.72	363.71	2713.92	2065.48	2014.19	1990.67	2562.09	2412.10	294.26
10.72	361.48	2624.91	1998.71	1949.32	1926.51	2475.92	2334.48	294.26
10.72	360.37	2580.46	1965.34	1916.89	1894.44	2432.94	2295.69	294.26
10.72	359.26	2536.04	1931.99	1884.47	1862.37	2390.03	2256.90	294.26
10.72	358.71	2513.85	1915.31	1868.26	1846.35	2368.60	2237.51	294.26

SUMS							AVERAGE
3859.17	2488.38	6694.72	20688.68	1701.01	42254.92	13182.66	3494.98
Energy Losses (kJ/kg of Dry Fuel)							Total
Flue Gas Constituent							Loss
CO2	O2	CO	N2	CH4	H2O Comb	H2O Fuel MC	Rate
140.17	270.03	40.18	1400.75	-130.83	1636.45	503.99	3860.74
156.66	261.20	36.45	1416.62	-112.74	1646.72	507.74	3912.65
150.84	167.16	42.23	1058.04	-66.50	1637.76	506.49	3496.02
157.78	142.30	62.73	988.28	-41.09	1640.46	508.15	3458.62
164.14	108.34	64.64	883.32	-21.56	1643.11	509.62	3351.62
197.92	46.96	92.09	758.33	23.55	1663.24	517.37	3299.47
198.07	34.41	1707.57	750.26	764.93	1609.11	525.78	5590.13
205.45	33.49	1018.20	751.44	451.52	1636.83	523.68	4620.61
175.20	23.68	2343.73	658.05	1057.70	1570.10	523.47	6351.93
195.03	34.15	821.36	718.35	361.11	1635.45	520.11	4285.56
177.77	107.79	31.26	919.97	-32.88	1653.78	512.55	3370.24
165.66	125.09	34.50	947.93	-42.84	1646.06	509.83	3386.24
158.24	117.67	34.22	899.46	-42.01	1640.57	508.16	3316.31
151.76	108.87	33.61	848.70	-40.19	1635.66	506.70	3245.10
155.94	78.74	57.77	751.69	-12.66	1636.11	507.74	3175.33
152.69	88.90	30.64	778.76	-31.10	1635.37	506.90	3162.16
141.48	81.93	40.67	720.94	-26.15	1626.76	504.40	3090.04
133.50	83.18	20.99	701.91	-38.55	1622.01	502.52	3025.56
122.52	82.00	21.64	665.54	-41.73	1614.27	500.02	2964.26
116.13	69.86	20.63	602.61	-36.92	1609.06	498.56	2879.94
113.40	69.10	20.74	591.83	-37.45	1607.10	497.94	2862.66
110.68	76.52	21.93	610.83	-43.20	1605.69	497.31	2879.77
106.94	74.38	32.95	592.13	-38.40	1602.50	496.48	2866.98
105.24	63.93	20.69	548.94	-37.26	1601.04	496.06	2798.64
103.43	67.29	21.32	555.86	-40.28	1600.01	495.65	2803.27
102.52	71.39	21.98	568.14	-43.49	1599.67	495.44	2815.67

SUMS						
16534	3231	13302.71	64835	3231	231.11	16.09
Total Loss	Chemical Loss 1	Sensible and Latent Loss	Total Output	Chem Loss 2	Grams Produced CO HC	
0	0	0.00	0	0	0.00	0.00
1414	-28	1441.18	5744	-28	1.29	-0.73
731	-5	736.39	3412	-5	0.87	-0.25
592	4	588.30	2798	4	1.05	-0.13
701	9	692.19	3443	9	1.32	-0.08
1067	37	1029.65	5337	37	2.91	0.14
2339	1022	1316.82	5949	1022	69.64	5.72
1933	608	1325.36	6354	608	41.55	3.37
2416	1279	1137.15	5118	1279	86.95	7.19
1141	311	829.54	4133	311	21.35	1.72
513	0	512.98	2501	0	0.47	-0.09
386	-1	387.33	1874	-1	0.39	-0.09
378	-1	379.28	1882	-1	0.38	-0.09
432	-1	432.86	2205	-1	0.44	-0.10
423	6	416.74	2214	6	0.75	-0.03
301	0	300.72	1583	0	0.29	-0.05
235	1	233.96	1272	1	0.30	-0.04
230	-1	231.47	1277	-1	0.16	-0.05
169	-1	170.25	961	-1	0.12	-0.04
164	-1	165.23	966	-1	0.12	-0.04
163	-1	164.26	967	-1	0.12	-0.04
110	-1	110.33	644	-1	0.08	-0.03
164	0	163.87	967	0	0.18	-0.04
160	-1	160.60	970	-1	0.12	-0.04
267	-2	268.34	1617	-2	0.20	-0.07
107	-1	107.90	646	-1	0.08	-0.03

Dirigo Laboratories, Inc.

Manufacturer: Arada
Model: Farringdon 16
Date: 2/21/2017
Run: 3
Control #: 035-S-075-1
Test Duration: 250
Output Category: 2

	HHV Basis	LHV Basis
Overall Efficiency	79.5%	85.9%
Combustion Efficiency	96.0%	96.0%
Heat Transfer Efficiency	82.8%	89.5%

HHV Output Rate (kJ/h)	15,379	14,589	(Btu/h)
Burn Rate (kg/h)	0.98	2.15	(lb/h)
Input (kJ/h)	19,348	18,353	(Btu/h)

Test Load Weight (dry kg)	4.1	9.0	dry lb
MC wet (%)	16.18		
MC dry (%)	19.30		
Particulate (g)	8.31		
CO (g)	231		
Test Duration (h)	4.166666667		

Emissions	Particulate	CO
g/MJ Output	0.13	3.61
g/kg Dry Fuel	2.04	56.79
g/h	1.99	55.47
lb/MM Btu Output	0.30	8.38

Air/Fuel Ratio (A/F)	9.75
----------------------	------

Test Results in Accordance with CSA B415.1-10

Default Fuel Values

	D. Fir	Oak
HHV (kJ/kg)	19,810	19,887
%C	48.73	50
%H	6.87	6.6
%O	43.9	42.9
%Ash	0.5	0.5